

CITY OF INDEPENDENCE
BUILDING DEPARTMENT
INGROUND POOL CONDITIONS

Enclosed please find a copy of the approved building/zoning permit for the referenced application, authorizing you to proceed with construction, but only subject to compliance with the following conditions:

1. Glare from lights used to illuminate the swimming pool area shall be directed away from all adjacent properties.
2. All gates for fence enclosure shall be self-closing and self-latching with latches placed at least four (4) feet above ground per Section P2601.9.0 of the 2002 KRC.
3. Pool has not been approved for a diving board.
4. Where the barrier of an in-ground pool is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the barrier. Spacing between vertical members shall not exceed 1 ¾ inches (44mm) in width per Section P2601.9.2 of the KRC.
5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is more than 45 inches (1143 mm), spacing between vertical members shall not exceed 4 inches (102 mm). Decorative cutouts shall not exceed 1 ¾ inches (44 mm) in width P2601.9.2.
6. Maximum mesh size for chain link fences that form an enclosure for an in-ground pool, shall be a 1 ¼ inch (32 mm) square unless the fence is provided with slats fastened at the top or the bottom which reduce the openings to not less than 1 ¾ inches (44 mm) P2601.9.2.
7. Where the barrier of an in-ground pool is composed of diagonal members, such as a lattice fence, the maximum opening form by the diagonal members shall be not more than 1 ¾ inches per Section P2601.9.2 of the 2002 KRC.
8. **The pool shall not be filled with more than 18 inches of water until the enclosure has been installed.**
9. The pool enclosure shall be designed and installed to withstand a horizontal concentrated force load of 200 pounds applied on a 1 square foot area at any point of the enclosure (fence) per Section P2601.9.2 of the 2002 KRC.

ABOVE GROUND POOL CONDITIONS

Enclosed please find a copy of the approved building/zoning permit for the referenced application authorizing you to proceed with construction, but only subject to compliance with the following conditions:

1. Glare from lights used to illuminate the swimming pool area shall be directed away from adjacent properties.
2. All gates for fence enclosure shall be self-closing and self-latching with latches placed at least four (4) feet above ground per Section P2601.9.1 of the 2002 KRC.
3. **The pool shall not be filled with more than 18 inches of water until the enclosure has been installed.**
4. The pool enclosure shall be designed and installed to withstand a horizontal concentrated force load of 200 pounds applied on a 1 square foot area at any point of the enclosure (fence) per Section P2601.9.2 of the 2002 KRC.